

City of Edwardsville			
Lead and Copper Sample Results			
Sample No.	Street	Copper (ug/L)	Lead (ug/L)
IEPA Maximum Contaminant Level		1300	15.0
4063028-01	400 Block of Roanoke Avenue	390	2.1
4063028-02	800 Block of Chancellor Drive	300	1.3
4063028-03	400 Block of W. Park Street	230	1.4
4063028-04	1300 Block of Eberhart Avenue	430	2.1
4063028-05	400 Block of W. 4th Street	100	<1.0
4063028-06	600 Block of N. Buchanan Street	91	3.1
4063028-07	700 Block of Roanoke Avenue	60	1.3
4063028-08	1600 Block of Prairieview Drive	230	9.7
4063028-09	800 Block of Chancellor Drive	310	2.5
4063028-10	900 Block of University Drive	15	<1.0
4063028-11	400 Block of Shady Lane	260	3.5
4063028-12	700 Block of Notre Dame Avenue	340	2.5
4063028-13	600 Block of Frederick Avenue	280	2.1
4063028-14	1400 Block of McCoy Drive	430	<1.0
4063028-15	600 Block of Frederick Avenue	490	1.3
4063028-16	800 Block of Ann Street	180	1.0
4063028-17	300 Block of East Lake Drive	440	2.9
4063028-18	1300 Block of Gerber Road	660	<1.0
4063028-19	200 Block of Circle Drive	200	1.1
4063028-20	900 Block of St. Louis Street	1300	2.3
4063028-21	800 Block of St. Louis Street	120	<1.0
4063028-22	800 Block of St. Louis Street	82	<1.0
4063028-23	800 Block of Grand Avenue	110	1.4
4063028-24	400 Block of W. 4th Street	480	<1.0
4063028-25	300 Block of Clay Street	98	2.0
4063028-26	300 Block of Clay Street	240	3.8
4063028-27	300 Block of Clay Street	210	2.0
4063028-28	300 Block of North Main Street	370	4.9
4063028-29	600 Block of Chapman Street	31	<1.0
4063028-30	500 Block of Hillsboro Avenue	20	<1.0

\*ug/L - Microgram per Liter